














PRODUCT SPECIFICATION COMPLIANCE TEST CERTIFICATE

WHITE WALL TILES

300 X 600mm

Pressed Ceramic Tiles International Norms ISO 13006-10545/98

GROUP: B3

No.	Icon	Test item	Unit	Requirements of Standard		Test result	Determination
1		Dimensional variation	(%)	length of side	+0.6 - -0.3	+0.3~-0.3	Qualified
2		Side straightness	(%)	±0.3		±0.3	Qualified
3		Squareness	(%)	±0.3		±0.3	Qualified
4		Surface flatness	(%)	Center curvature degree	+0.8 - -0.2	< 0.4	Qualified
				Warping degree	±0.75	< 0.4	Qualified
				Side curvature degree	+0.8 - -0.2	< 0.4	Qualified
5		Surface quality	—	Sighting vertically at a distance of 0.8 meter away from the tile no defect on surface is observed in at least 95% of the tile		conformed	Qualified
6		Water absorption	(%)	Average value >10 = E > 10-15 individual > 10-15		>12 >12	Qualified
7		Breaking strength	N	When thickness ≥7.5mm the Average value ≥600		> 600	Qualified
8		Rupture modulus	Mpa	Average value ≥15		> 15	Qualified
9		Abrasion resistance	mm ³	n.a. for wall tiles		—	n.a.
10		Stain resistance				Class 3	Qualified
11		Frost resistance	—	No cracking after test		conformed	Qualified
12		Resistance to acids & alkalis	—	To be declared		Grade GLB	Qualified
13		Chemical resistance	—	Not less than grade GB		Grade GB	Qualified