

科达陶瓷产品质量检测报告
KEDA TEST REPORT

(T—QC—TTR—2020)

No. 2023-5-30

抽样方式 Sampling method	随机 Random	抽样地点 Sampling location	成品仓库Warehouse	抽样时间 Sampling time	30. May. 2023
产品类型 Product type	仿古砖 Procelain tile	表面属性 Nature of surface	有釉/GL	规格/Spec.	600*600*9.8 mm
性能 Characteristic	要求 Requirements	检测结果 Results	检测方法 Test method	判定 Pass/Fail	
标识 Mark	砖和包装标识 Tile or packaging marking	依据 TZS 954 According to TZS 954	---	---	---
		商标 Trade mark	已标识 Marked	---	合格/Pass
		原产国家 Country of origin	已标识 Marked	---	合格/Pass
		参考标准 Reference standard	已标识 Marked	---	合格/Pass
		产品等级 Grade of tiles	已标识 Marked	---	合格/Pass
		表面属性 Nature of surface	已标识 Marked	---	合格/Pass
		工作尺寸 Work size	已标识 Marked	---	合格/Pass
尺寸和表面质量 Dimensions and surface quality	长度 Length	600±2.0 mm	599.9 mm	ISO10545—2	合格/Pass
	宽度 Width	600±2.0 mm	600.2 mm	ISO10545—2	合格/Pass
	厚度 Thickness	9.8±0.4 mm	9.8-10.0 mm	ISO10545—2	合格/Pass
	中心弯曲度 Centre curvature	±2.0 mm	-0.2~+0.45 mm	ISO10545—2	合格/Pass
	边弯曲度 Edge curvature	±2.0 mm	-0.2~+0.4 mm	ISO10545—2	合格/Pass
	表面质量 Surface quality	至少95%的砖其主要区域无明显缺陷 At least 95% of the bricks have no significant defects in their main areas	无明显缺陷 No visible defects	ISO10545—2	合格/Pass
物理性能 Physical property	吸水率 Water absorption	吸水率标准小于等于0.5% Less than or equal to 0.5%	平均0.03% Average value 0.03%	ISO10545—3	合格/Pass
		单个值不大于0.6% A single value is not greater than 0.6%	最大值0.08% Maxmum value 0.08%		合格/Pass
	破坏强度 Breaking strenth	标准大于等于1700 N Standard is greater than or equal to 1700 N	1812 N	ISO10545—4	合格/Pass
	断裂模数 Mudulus rupture	平均值大于等于35 MPa，单个值大于等于32 MPa The average value is greater than or equal to 35 MPa, and the single value is greater than or equal to 32 MPa	32.43 MPa	ISO10545—4	合格/Pass
	抗热震性/Thermal shock resistance	报告检验结果 Declear value	样品经实验，无裂纹或剥落 No crack or chipping	ISO10545—9	合格/Pass

科达陶瓷产品质量检测报告
KEDA TEST REPORT

(T-QC-TTR-2020)

No. 2023-5-30

抽样方式 Sampling method	随机 Random	抽样地点 Sampling location	成品仓库Warehouse	抽样时间 Sampling time	30. May. 2023
产品类型 Product type	仿古砖 Procelain tile	表面属性 Nature of surface	有釉/GL	规格/Spec.	600*600*9.8 mm
性能 Characteristic	要求 Requirements		检测结果 Results	检测方法 Test method	判定 Pass/Fail
化学性能 chemical property	耐污染性 Resistance to staining	最低3级/Minimum level 3	2级/Level 2	ISO10545-14	合格/Pass
	耐低浓度酸和碱 Resistance to low concentrations acids and alkalis	制造商报告耐化学腐蚀性等级 Manufacturer is to state classification	ULA	ISO10545-13	合格/Pass
	耐高浓度酸和碱 /Resistance to high concentrations acids and alkalis	制造商报告试验方法 test method available	UHA	ISO10545-13	合格/Pass
	家庭化学试剂和游泳池盐类 Resistance to household chemicals and swimming pool salts	报告检验结果 Declare value	UA	ISO10545-13	合格/Pass
用语说明 Remark	P(PASS) 合格——TEST ITEM DOES MEET THE REQUIREMENT F(FAIL) 不合格——TEST ITEM DOES NOT MEET THE REQUIREMENT - 未进行判定——VERDICT IS NOT CARRIED OUT N/A 不适用——TEST CASE IS NOT APPLY TO THE TEST ITEM				

报告Reported by: GODY

批准/Approved by:

黄余城